

## SK CERTIFICATE

of constancy of performance of the essential characteristics of the construction product  
**SK03 - ZSV - 0587**

In compliance with Act No. 133/2013 Coll. of Laws on construction products and on amendments to certain laws, this certificate applies to the construction product

### Powder fire extinguishing modules TUNGUS

**Type:** **TUNGUS 065** (MPP(N)-065-I-GE-U2)  
**TUNGUS 2** (MPP(N)-2-I-GE-U2)  
**TUNGUS 4** (MPP(N)-4-I-GE-U2)  
**TUNGUS 5** (MPP(N)-5-I-GE-U2)  
**TUNGUS 6** (MPP(N)-6-I-GE-U2)

**TUNGUS 9** (MPP(N)-9-I-GE-U2)  
**TUNGUS 10** (MPP(N)-10-I-GE-U2)  
**TUNGUS 10st** (MPP(N)-10(st)-I-GE-U2)  
**TUNGUS 24** (MPP(N)-24-I-GE-U2)

intended for fire protection of buildings and technological equipment against fires class A, B, C and E.  
They can work in automatic or manual mode.  
Modules in design (N) are not intended for use in the risk of explosion

produced for

**Technopark PS s.r.o, Záhradná 19, 900 24 Veľký Biel, Slovak Republic**

and produced in the manufacturing plant

**ZAO „Istochnik Plus“, 1 Socialisticheskaya St., 659322 Biysk, Altay region, Russian Federation**

This certificate attests that all provisions concerning the assessment and verification of constancy by manufacturer declared performance of the essential characteristics of the construction product (hereinafter "assessment of performance") and the performances described in Slovak technical assessment

**SK TP - 14/0080**

under system of assessment of performance I are applied and that

**the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on September 12th, 2014 and will remain valid as long as the SK technical assessment, remains valid and the manufacturing conditions in the plant or the factory production control itself are not modified significantly.



Piešťany September 12th,

Ing. Janka LEVICKÁ  
on behalf of authorized body